



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---|---|----------|----------|--|
| 1 | OHP | CO 67 | olr acted | reset it done | 03:30:00 | 03:35:00 | |
| 2 | OHP | co 26 | olr acted | reset | 00:25:00 | 00:30:00 | |
| 3 | OHP | CO 49 | olr acted | reset | 00:20:00 | 00:40:00 | |
| 4 | OHP | TT 3 | position indication not healthy | fuse blown,fuse replaced | 03:15:00 | 03:30:00 | |
| 5 | OHP | CO 33M | olr acted | reset | 04:55:00 | 05:00:00 | |
| 6 | OHP | CO 29 | olr acted | reset | 05:00:00 | 05:15:00 | |
| 7 | OHP | CO 35 | OLr acted | reset | 03:20:00 | 03:30:00 | |
| 8 | OHP | TBS on CO 5A | no power,acb is in off | acb made on | 05:20:00 | 05:30:00 | |
| 9 | OHP | CO 35 | Emergency PB 2 (YARD)acted | PB ok return side high also coming, cable fully jammed under material | 23:00:00 | 23:20:00 | Emergency PB 2 yard side bypass in program, to be checked in general shift |
| 10 | CHP | CC 29 on 111 | bit was missing,i/o rack cable was loose connection | tightened it | 00:50:00 | 01:05:00 | |
| 11 | CHP | CC 51 | mpd tripped on OL | reset | 22:30:00 | 06:00:00 | 5 times |
| 12 | CHP | CC 54 | motor tripped in OLR | reset | 22:50:00 | 22:55:00 | |
| 13 | CHP | CC 52 | TIS motor tripped on overload due to scrap metal | reset | 01:10:00 | 01:20:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---|---------------------------------|----------|----------|---------|
| 14 | CHP | CC 31 | olr acted | reset | 23:30:00 | 23:40:00 | |
| 15 | CHP | CC 31 SCR4 | LT not taking,motor mpcb tripped,track full jamming | informed operation,mpcb made on | 23:45:00 | 23:55:00 | |
| 16 | CHP | CC 33 SCR5 | b/w not running,b/w stucked in coal heap | LT rev done than ok | 00:10:00 | 00:20:00 | |
| 17 | CHP | CC 37 SCR 7 | LT not taking place,OT acted | OT released | 02:45:00 | 02:55:00 | |
| 18 | CHP | CC 33 SCR 5 | b/w not running,low ACC pressure p2 | informed mech | 05:15:00 | 05:30:00 | |