



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 18/10/2025

Incharge(s): Lal Singh

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|--------------|---------------------------------|--|----------|----------|---------|
| 1 | OHP | RSCO-10A | TRIPPED ON OLR | RESET DONE | 23:00:00 | 23:15:00 | |
| 2 | OHP | BRC ON CO-31 | BC TRIPPED ON OLR | RESET DONE | 00:25:00 | 00:40:00 | |
| 3 | OHP | TBS ON CO-7A | LBC NOT RUNNING | DUE TO MATERIAL JAMMING AND OFFCENTRING ... INFORMED OPERATION | 02:05:00 | 02:15:00 | |
| 4 | OHP | DB-1 | TRIPPED ON OLR | RESET DONE | 05:30:00 | 05:40:00 | |
| 5 | CHP | CC-34 SCR-2 | SIGNAL MISSING | LT DONE THEN OK | 00:00:00 | 00:20:00 | |
| 6 | CHP | CC-33 SCR-5 | LT NOT WORKING .. PCRD OT ACTED | RELEASED | 03:45:00 | 04:00:00 | |
| 7 | CHP | CC-51 | TRIPPED ON OLR | RESET DONE | 01:40:00 | 01:45:00 | |
| 8 | CHP | CC-54 | TRIPPED ON OLR (4 TIMES) | RESET DONE | 00:40:00 | 05:05:00 | |
| 9 | CHP | VF-3 | TRIPPED ON OLR | RESET DONE | 23:40:00 | 23:45:00 | |
| 10 | WT | OT-1 | D1 TRIPPED ON PGF1 FAULT | RESET DONE | 02:20:00 | 02:25:00 | |