



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/07/2025

Area: OHP

Equipment	Job
brc-4 on co-34	rtd cable to io rack checked, insulated at few places and restored temperature interlock in circuit.