



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 15/12/2025

Area: IOSA

Equipment	Job
OC-6A	CONVEYOR GALLERY LIGHTING CIRCUIT DEFECTS RECTIFICATION DONE. LIGHTS TO BE PROVIDED.
OC-7A	HEAD END HOIST MOTOR REPLACEMENT IS IN PROGRESS.
WOBR-FLS	MAINTENANCE DONE ON MCC PANEL, PLC PANEL.
OC-27A	SWITCH BOARD SUPPLY AND LIGHTING PROVIDED FOR BELT HOT JOINT.
OC-21A	SWITCH BOARD SUPPLY AND LIGHTING ARRANGED FOR BELT JOINTING JOB.
COMPRESSOR HOUSE	ELECTRICAL HOIST NOT WORKING. CHECKED THE CIRCUIT AND RESTORED CONTROL SUPPLY. TESTING DONE.
TBS	PCRD CABLE GUIDE CHAIN TENSION UNIT GOT DAMAGED. HT CABLE LOOP GIVEN AND GIVEN CLEARANCE.
OC-23A	PPM DONE ON FIELD DEVICES.