



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 28/07/2025

Area: IOSA

Equipment	Job
BRC HARROW-2	BRAKE PANEL CONNECTIONS GIVEN AND CHECKED THE EM BRAKE OPERATION.
OC-27A	LEFT REAR PULL CHORD CHECKED AS INDUCTION VOLTAGE IN RETURN WIRE TO PLC
MISC	OC-19A,21A,23A CONVEYOR GALLERY WELDING SOURCES, MCBDBS,SLDBS MAINTENANCE AND DEFECTS RECTIFICATION
WOBR-L and T	TRIAL RUN DONE AND CHECKED HYDRAULIC POWER PACK.
OC-11A	PPM DONE ON FIELD DEVICES.