



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/02/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO 1A	CD MPCB TRIPPED	RESET	10:50:00	11:00:00	
2	OHP	CO 16	OLR ACTED	RESET	13:00:00	13:10:00	
3	CHP	CC 28	OLR ACTED	RESET	07:20:00 08:00:00	07:25:00 08:05:00	
4	CHP	CC 29	OLR ACTED	RESET	12:30:00	12:35:00	
5	CHP	CC 51	FEEDING CONV MPD ACTED	RESET	06:50:00	08:20:00	5 TIMES
6	CHP	CC 54	OLR ACTED	RESET	07:30:00	08:25:00	6 TIMES
7	CHP	CC 58	OLR ACTED	RESET	09:40:00	09:55:00	
8	WT	CO 3	OLR ACTED	RESET	11:10:00	11:15:00	