



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 23/01/2026

Area: CHP

| Equipment | Job |
|---------------------------------------|---|
| CC 107/108 tunnel | 5 nos 30W lamps replaced |
| CC 114 | 4 nos lamp fixtures replaced |
| LC 17,CM 19 | IO rack prophie bus cable loopings replaced with new ones |
| SCR 7,S2,SCR 2,6 | Machine to yard focusing lamp fixtures replaced |
| SCR 3 | LT panel door fixed |
| All Hoists | Total CHP JH Hoists inspected with external agency |
| CC 107,205,206,207,208,209,210,211 | PPM was done |