



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/05/2025

Area: WT

Equipment	Job
OP 9	modification job, all control cables removed from panels and 24 V relays fixed in drive panels
	after rake maintenance done

OP 3 & 6