



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 31/05/2025

Area: CHP

| Equipment | Job |
|--------------|---|
| SCR 1 to 10 | Cable chamber inspection was done |
| Stacker 3 | Running inspection was done |
| SCR 7 | HT cable dressing done |
| CC 223 | Drive end and gallery lighting ckt problems rectified and improved lighting |
| CC 27,27A,46 | PPM was done |
| Reclaimer 1 | Slew one end limit Proximity switch and AUX. relay replaced and tested the limits |