



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/10/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--------------------------------------|--------------------|----------|----------|---------|
| 1 | OHP | wobr on co 25 | bc not running,CS acted | reset | 09:38:00 | 09:45:00 | |
| 2 | OHP | co 29 | olr acted | reset | 06:50:00 | 06:55:00 | |
| 3 | OHP | co 29 | olr acted | olr acted | 12:50:00 | 13:00:00 | |
| 4 | OHP | co 84 | olr acted | reset | 13:50:00 | 14:00:00 | |
| 5 | OHP | OP 7 | no reverse movement,rev lt acted | rev limit released | 09:00:00 | 09:10:00 | |
| 6 | CHP | CC 114 | olr acted | reset | 09:40:00 | 09:45:00 | |
| 7 | CHP | BRC on co 30 | b/c not running,Cs acted | reset | 11:45:00 | 11:59:00 | |
| 8 | CHP | CC 45 | olr acted | reset | 09:00:00 | 09:05:00 | 2 times |
| 9 | CHP | CC 34 SCR2 | slew not working,jamming | informed operation | 10:55:00 | 11:05:00 | |
| 10 | CHP | CC 112 SCR 8 | Lt not working,PCRD gear box damaged | informed mech | 10:40:00 | 10:50:00 | |
| 11 | CHP | CC 28 flap gate | mpcb trips | made it on | 13:25:00 | 13:35:00 | |
| 12 | WT | CP 4 | communication problem | power recycled | 07:00:00 | 07:05:00 | |
| 13 | WT | co 3 | olr acted | reset | 09:15:00 | 09:25:00 | |
| 14 | WT | OP 9 | not moving,rake is in decoupled | informed operation | 12:15:00 | 12:30:00 | |