



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment    | Problem   | Action                                    | From     | To       | Remarks  |
|-------|------|--------------|---|---|----------|----------|--|
| 1     | OHP  | CR 1         | SHOWING OIL LOW LEVEL   | SENSOR ADJUSTED                           | 06:30:00 | 06:40:00 |  |
| 2     | OHP  | CO 43A       | NO POWER CONTROL MCB TRIP DUE TO PULL CHORD EARTH FAULT       | FIELD WIRES REMOVED AND PC BYPASS THAN OK | 07:30:00 | 08:00:00 |  |
| 3     | OHP  | WOBR ON CO29 | CABAN ADJUSTMENT DRIVE NOT WORKING CABLE GOT CUT              | JOINT DONE THAN OK                        | 07:00:00 | 07:30:00 |  |
| 4     | OHP  | BRC ON CO 8A | B/C OLR ACTED   | reset it done                             | 07:45:00 | 11:00:00 | belt fully loaded with material//// 3 times          |
| 5     | OHP  | BRC on 32    | CT not working, limit acted operator cabin side               | limit released                            | 12:00:00 | 12:40:00 |  |
| 6     | OHP  | CO 35        | olr acted   | reset it done                             | 12:30:00 | 12:40:00 |  |
| 7     | CHP  | CC 40 scr 6  | b/c not running, c/s acted, full jamming                      | informed operation                        | 07:20:00 | 07:30:00 |  |
| 8     | CHP  | CC 39        | OLR acted   | reset it done                             | 07:45:00 | 07:50:00 |  |
| 9     | CHP  | CC 39 SCR 7  | slew not working, break fail alarm in spider                  | reset it done                             | 08:30:00 | 08:40:00 |  |
| 10    | CHP  | CC 32 SCR 5  | slew complaint, wrong complaint, LT not working, mpcb 2 trips | made it on                                | 09:30:00 | 09:40:00 |  |
| 11    | CHP  | CC 44        | olr acted   | reset it done                             | 11:20:00 | 11:25:00 | 5 times, belt full load condition informed operation |



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

| Sl No | Area | Equipment     | Problem                 | Action                             | From     | To       | Remarks                        |
|-------|------|---------------|-------------------------|------------------------------------|----------|----------|--------------------------------|
| 12    | CHP  | CC 36<br>SCR1 | BC position not showing | position bit bypass in i/o rack    | 11:00:00 | 11:15:00 | magnetic switch to be replaced |
| 13    | CHP  | CC 54         | olr acted               | reset it done                      | 07:30:00 | 07:40:00 |                                |
| 14    | IOSA | oc 7a 2a 3a   | showing red             | lbds 2 plc power re cycled than ok | 09:00:00 | 09:20:00 |                                |