



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 02/12/2025

Area: OHP

Equipment	Job
co-16 h/e mldb	fault is rectified and restored illumination.
co-9a h/e and gallery ; 12a gallery ; 44 tis area ; 10a gallery ;13a h/e	illumination is improved.
unit-2 beltscale areas	lighting is improved.
co-68 zss probe changed	and restored in circuit.
co-68 gallery ;	illumination is improved.
brc-1 on co-30	ppm is done ; selctor switched is fixed and 7c*1.5 cable laid from operator cabin to ct vfd panel. lighting is improved.
co-22, 21, 19,20,7a beltsways	switches replaced, circuit problems rectified and checked till io rack to be kept in circuit.