



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 24	no power /checked and found HT FUSES 3 NOS BLOWN and COUPLER GOT FLASHOVER due to moisture in coupler	coupler cleaning and blowring done meggering done,HT FUSES REPLACED FROM CO 23 COUPLER then power made on and tested ok/coupler heater power made on	02:30:00	04:30:00	heater power was off for coupler
2	OHP	brc on co 28	It not taking place/pcrd tension acted	pcrd tension released	03:00:00	03:15:00	2 times
3	OHP	wobr on co 26	slew not taking place	power recycle done	01:20:00	01:35:00	
4	OHP	TT 4 ON BYPASS 1	It not taking place/mpcb tripped	mpcb made on	01:40:00	01:55:00	
5	OHP	co 111	reportd red /mpcb tripped	mpcb made on	03:15:00	03:25:00	
6	OHP	CO 12(c)	mpcb trips	made it on	05:40:00	05:49:00	
7	CHP	scr 1 on cc35	luffing up not taking place/boom fulldown	inform to mech	02:20:00	02:35:00	
8	CHP	scr 6 on cc40	bw not working	wrong complaint	00:45:00	00:50:00	
9	CHP	scr 10 on cc105	bc not running/signal problem	yard inter lock kept in ckt	01:28:00	01:40:00	
10	CHP	cc47	brs acted/	reset done	01:30:00	01:45:00	
11	CHP	cc 201,203	tripped on olr	reset done	23:19:00	23:28:00	
12	CHP	cc 131	tripped on olr	reset done	00:00:00 01:45:00	00:05:00 01:50:00	
13	CHP	cc54	tripped on olr	reset	01:45:00	01:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 10/07/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	cc 51	tripped onmpd	reset	01:30:00	01:35:00	due back feeding stop