



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/01/2026

Shift: A

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 67	olr acted	reset	08:25:00	08:30:00	
2	OHP	co 26	olr acted	reset	09:15:00	09:25:00	
3	OHP	TIS 2	failed to start,push button problem	push button replaced	08:30:00	08:50:00	no delay
4	CHP	CC 39 SCR6	all drive not working,main contactor not pickup,ePB @operator cabin NO contact problem	bypassed contact and informed G shift	08:30:00	08:40:00	
5	CHP	CC 201	olr acted	reset	08:55:00	09:00:00	
6	CHP	CC35 scr3	b/c not running,olr acted	reset	09:25:00	09:35:00	
7	CHP	CC 32	yard conveyor not working,mpd tripped	reset	08:10:00	08:15:00	
8	CHP	CC 51	MPD acted 3 times	reset	07:20:00	07:25:00	
9	CHP	CC 131	olr acted	reset	13:45:00	13:50:00	
10	WT	CT	communication problem	modem replaced,and configuration done in modem	06:00:00	06:45:00	
11	WT	OP4	no movement,communication problem	LC1 and LC2A side modem power recycle done and ethernet cable plugged and unplugged	13:30:00	14:00:00	