



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/12/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 13 (c)	olr acted	reset	22:30:00	22:40:00	
2	OHP	BRC on co 8A	CT not working,drive tripped	reset	22:30:00	22:45:00	
3	OHP	BRC on CO 32	B/W2 not running,stone stucked	informed operation	23:45:00	00:00:00	
4	OHP	CO 30	olr acted	reset	23:33:00	23:42:00	
5	OHP	WOBR on co 25	LT not working,OT acted	OT released	01:45:00 04:00:00	02:00:00 04:15:00	2 times
6	OHP	CO 26	OLR acted	reset	04:20:00	04:30:00	
7	OHP	CO 13(B)	mpcb tripped,due to jamming	reset	23:00:00	23:10:00	3 times
8	CHP	CC 38 SCR 6	luffing not working B shift complain	motor megger done (Bph-E )zero,old motor removed power cable connected to spare motor(spare motor meggered value 10 Mohm),direction checked and clearance given	22:00:00	23:50:00	
9	CHP	CC 39 S1	slew not working,start Pb loose connection	tighetened	22:50:00	23:00:00	
10	CHP	CC 47	fail to start	power recycle done than ok	00:00:00	00:10:00	
11	CHP	CC 112 SCR8	LT not working	wrong complaint	01:30:00	01:40:00	
12	CHP	CC 32 SCR 5	slew not working,left limit acted	right done than ok	03:30:00	03:45:00	
13	CHP	CC 38 SCR 6	Lt not woking,M2mpcb tripped,tracked jamming	mpcb made on ,informed operation	05:35:00	05:45:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 12/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 54	olr acted	reset	23:00:00	06:00:00	10 times
15	CHP	CC 51	mpd tripped	reset	01:00:00	01:05:00	
16	CHP	CC 58	olr acted 3 times	reset	02:55:00	03:35:00	
17	CHP	CC 132	olr acted	reset	04:15:00	04:25:00	
18	WT	OT 1	D1 tripped in pgf1 fault	reset	05:00:00 05:45:00	05:05:00 05:50:00	