



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 29/09/2025

Area: WT

Equipment	Job
OT 1 and 2	Panels and Encoder JBs blowing and termination checking done
SCO 1A	Field control cable checked ,found earth fault in Belt Way switch,isolated it.
OC1A level	Lighting job done ,50 W LED bulbs 2 nos replaced
OP 3,4 and 6	After rake maintenance done