



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 07/06/2025

Area: CHP

Equipment	Job
CC 222	Lighting ckt rectification done and improved lighting
CC 38	Mechanical BRS installed with control unit and kept in ckt
SCR 8	LT end limit tested
S 3	HT cable joint done by DNW, terminations done, fuses replaced and power charged
CC 7,8,9	BRS maintenance was done