



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 07/05/2025

Area: IOSA

Equipment	Job
BLENDER RECLAIMER	MACHINE SKEW LT LIMIT SWITCH FEEDBACK NOT COMING. KEPT IN BYPASS.
BLENDER RECLAIMER	LT MOTOR-4 GEAR BOX MECHANISM FIXING ROD WELDING HAS COME OUT AND WHOLE UNIT ALONG MOTOR GOT TILTED. MOTOR TERMINATION DONE AFTER MECH. JOB COMPLETION
OC-7C	MOTOR AND FIELD DEVICES PPM DONE.
LIGHTING	BATTERY ROOM LIGHTING DEFECTS RECTIFIED AND HOUSE KEEPING DONE.
OC-7A	CONTROL AND BUS PT SEC. VOLTAGES CHECKED AND FOR ANY LOOSE CONNECTIONS
1-28HVMCC-5	OC-7A, OC-2A MPR RELAY SETTINGS CHECKED.
LIGHTING	LIGHTING DEFECTS RECTIFIED IN OC-29A GALLERY