



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 30/08/2025

Area: WT

| Equipment | Job |
|-----------------|---|
| CO 5,6,7 Tunnel | Lighting improved ,120W 2nos and one 200W LEDs replaced |
| OP 9 | panel and motor side ppm done |
| MIs | RMD room near E-Goomty,supply problem, found R-phase cable fault and changed to B-phase |
| OP 10 | LOTUS modem checked, found fixing position changed,fixed it properly ,now OK |
| Mis | Key made ready and coupling fixed to OP1 ,D4 motor |
| OP 4 and 5 | After rake maintenance done |