



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/11/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO 30	b/c olr acted	reset	23:50:00	00:00:00	
2	OHP	CO 19 TBS	Left bc not running, stopping in zss, sometimes	zss bypassed	00:00:00	00:30:00	module to be checked
3	OHP	CO 29	OLr acted	reset	03:50:00	04:00:00	
4	OHP	CO 62(B)	mpcb tripped due to jamming	made on	01:00:00	01:05:00	
5	OHP	TIS 1 on co 5	not healthy, emergency acted by mechanical, v belt problem	bypassed and emergency released	23:40:00	00:00:00	
6	OHP	TIS 2	not healthy, emergency acted by mechanical,	emergency released	02:00:00	02:10:00	not electrical delay
7	OHP	TIS 3	not healthy, power mpcb tripped	made it on	02:10:00	02:15:00	
8	OHP	CO 11	chute sensor acted, earth fault	bypassed	04:10:00	04:15:00	checking going on
9	CHP	CC 51	mpd acted	reset	00:45:00	00:50:00	2 times
10	CHP	CC 131	olr acted	reset	00:01:00	05:35:00	5 times
11	CHP	CC 54	OLR acted, 5 times	reset	04:50:00	05:25:00	
12	CHP	CC 103	fail to stop, mechanical gear box oil empty	informed mechanical	22:35:00	22:45:00	
13	CHP	CC 28	healthy stop, cc28 and cc29 tt on 31	cc 29 TT on 31 removed	00:40:00	00:55:00	
14	CHP	CC 110	zss acted, wrong complaint	checked and given clearance	00:30:00	00:40:00	
15	CHP	CC 44	olr acted	reset	22:45:00	22:55:00	
16	CHP	CC 125	olr acted	reset	01:05:00	01:15:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 08/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	CHP	CC 38 SCr6	LT not working,drive tripped	reset	01:25:00	01:40:00	
18	CHP	CC 37 scr 7	b/c not running,olr acted	reset	01:30:00	01:40:00	2 times
19	CHP	CC 45	olr acted	reset	03:10:00	03:20:00	3 times
20	WT	OT 4	initial not coming	sensor adjusted than ok	00:30:00	00:45:00	