



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/10/2025

Shift: C

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT- 3 ON BPC-2	POSITION SIGNAL NOT COMING	WIRE LOOSE ... FIXED PROPERLY	23:00:00	23:10:00	
2	OHP	BRC ON CO-8A	CT NOT WORKING	CABIN SIDE LIMIT STUCK ... RELEASED	01:10:00	01:25:00	
3	OHP	BRC ON CO-34	BW -2 OLR ACTED ...	RESET DONE	01:25:00	01:40:00	
4	OHP	CR-1	TRIPPED ON OVER CURRENT	RESET DONE ANDE TESTED	01:40:00	01:50:00	
5	OHP	RCO-6A	TRIPPED ON OLR	RESET DONE	03:30:00	03:35:00	
6	OHP	CO-62 BD	MPCB TRIPPED	RESET DONE	03:10:00	03:20:00	
7	OHP	CO-63	CHUT SENSOR NOT HEALTHY	CHUT JAM ... INFORMED OPERATION	23:10:00	23:20:00	
8	OHP	BRC ON CO-32	BW -1 IS NOT MOVING	DUE TO HAVEY LOAD ... LOAD CLEARED BY MANUALLY PRESSING SOLENOID	02:55:00	03:05:00	
9	OHP	CO-26	TRIPPED ON OLR	RESET DONE	04:25:00	04:30:00	
10	OHP	BRC-32	HYDRAULIC PUMP NOT RUNNING .. NO SUPPLY TO DMPR	230V SUPPLY TO DMPR TRACED AND FOUND NEUTRAL WIRE LOOSE IN MCB IN LIGHTING PANEL ... FIXED PROPERLY	04:45:00	05:20:00	
11	CHP	CC-104 SCR-9	SLEW NOT WORKING	ABC TRIPPED ... RESET DONE	23:30:00	23:40:00	
12	CHP	CC-112 SCR-8	BC STOPPING IN BETWEEN	NO ELECTRICAL PROBLEM ... CHECKED AND FOUND RUNNING CONTINUOUSLY	01:30:00	02:00:00	
13	CHP	CC-51	MPD TRIPPED 6 TIMES	RESET DONE	23:00:00	06:00:00	
14	CHP	VF-2	TRIPPED ON F021 FAULT	RESET DONE	01:00:00	01:05:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/10/2025

Incharge(s): K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	WT	OT-1	D1 TRIPPED ON PGF FAULT ... 3 TIMES	RESET DONE	02:10:00 03:30:00 23:30:00	02:15:00 03:35:00 23:35:00	
16	WT	OC -1A BD	TRIPPED ON OLR	RESET DONE	04:20:00	04:25:00	
17	IOSA	OC-7B	FAIL TO START	POWER RECYCLED AND TESTED	02:30:00	03:00:00	