



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 27/09/2025

Incharge(s): Amit Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT2	CHUTE VIBRATOR	MOTOR BURNT	17:10:00	17:30:00	
2	OHP	CO 26 WBR	LUFF 24V FUSE BLOWN	REPLACED	15:45:00	16:00:00	
3	OHP	CO 13	CARRIAGE DRIVE MPCB TRIPPED	MADE IT ON	21:40:00	21:50:00	
4	OHP	TBS ON CO 7A	BREAK MPCB TRIPPED	MADE IT ON	21:30:00	21:45:00	
5	CHP	CC 51	MPD TRIPPED	RESET	15:20:00	15:30:00	
6	CHP	S1 ON CC 39	LT POTENTIOMETER	REPLACED	16:25:00	16:55:00	
7	CHP	SCR 3 ON CC 490	LUFF OLR ACTED	RESET	15:45:00	16:00:00	
8	CHP	SCR 3 ON CC 40	SLEW OIL LEVEL LOW	INFORMED TO MECH	20:20:00	20:30:00	
9	CHP	CC 203	CC 28 RUNNING SIGNAL NOT COMING	COMMUNICATION PROBLEM CHECKING UNDER PROGRESS	21:20:00	22:00:00	
10	WT	CP1	COMMUNICATION FAULT	POWER RECYCLED	18:00:00	18:20:00	