



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 22/11/2025

Area: WT

Equipment	Job
MIS	2 nos remotes for E O T cranes ( coal and ore) recived and tested ,OK
OP 6	Main cantactor in side the pusher ( vaccum 3TF68) replaced and tested
OP 6	D5 checked found winding earth fault in side motor ,packing provided,
LC 2A and 2B	ground sub station panel maintenance done for OP 1 to 5,7 and 8
OP 1,2,6 and 7	after rake maintenance done