



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/01/2026

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-56	ZSS acting	Cage stuck up with stone.Made free and tested okay	10:30:00	10:45:00	
2	CHP	CC-54	Reported tripped	OLR acted.Reset done(3 times)	07:30:00	10:30:00	Ran in local to clear material
3	CHP	Cc-58	Reported tripped	OLR acted due to over material on belt.Reset done	08:20:00	08:25:00	
4	CHP	LC-15,16	Reported all conveyors no power.Tripped due to breaker tripped in LBDS feeder 2.	Feeder 2 kept off in LBDS and power normalized in LC-15,16 and tested okay	10:20:00	10:45:00	Feeder no.2(panel no.34) racked out in LBDS for DNW work
5	CHP	CC-105 SCR-10	LT not taking place	PCRD tension acted.Released	07:50:00	08:00:00	
6	CHP	CC-9	Reported tripped	OLR acted.Reset done	13:50:00	13:55:00	
7	CHP	CC-216	Reported tripped	OLR acted.Reset done	08:40:00	08:50:00	
8	CHP	Cc-31 SCR-4	B/C not running	CJD acted.Cleaning done and tested okay	09:15:00	09:30:00	
9	CHP	CC-219	ZSS acting	Module problem.Replaced and tested okay	07:30:00	08:00:00	
10	CHP	CC-107	Reported tripped	OLR acted.Reset done	11:30:00	11:35:00	
11	CHP	Cc-31	Reported tripped	OLR acted.Reset done	11:52:00 13:30:00	12:00:00 13:35:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 26/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC-125	Reported tripped	OLR acted.Reset done	13:20:00	13:25:00	
13	CHP	CC-108	Reported tripped	OLR acted.Reset done	13:30:00	13:35:00	
14	WT	OT-1,2,3,4	Reported no power	OM-4 tripped due to power dip.Breaker made on and tested okay	10:20:00	10:30:00	
15	WT	OP-5	Reported not moving	D-4 tripped.Reset done	10:30:00	10:35:00	