



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL GENERAL SHIFT REPORT

Date: 31/12/2025

Area: CHP

Equipment	Job
Misc	CM-9 to JH-3 three phase welding machine supply cable lugging done and termination done
CC-13	MCCB outgoing jumpers changed and kept in line
LBDS-8 to LC-2 cable	cable laying completed. Junction box to be fixed and connections pending
Misc	Mechanical BRS preparation is under progress
CC-33 BRS	Sensors alignment done
SCR-7 LIGHTING	Lighting rectification done. 30W- Led lights 10no's installed
STK-2	Modem configuration done and installed. Communication checked and found ok
CC-49 and CC-50 SPARE MOTOR	spare motor coupling removed and fixed to the motor recently came from ERS (2606/25) after overhauling. Motor shifted to spare location