



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/11/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--|---|----------|----------|---------|
| 1 | OHP | CO-29 | REPORTED BRS NOT HEALTHY FOUND GLASS FUSE BLOWN IN BRS PENAL | GLASS FUSE REPLACED THAN BRS RESET DONE | 06:45:00 | 07:10:00 | |
| 2 | OHP | TBS ON CO-22 | REPORTED C/S NOT WORKING CHECKED WITH INSTRUMENTATION PRESENCE | COMMUNICATION PROBLEM THAN CLEARANCE GIVEN | 09:00:00 | 09:20:00 | |
| 3 | OHP | CO-63 | TRIPPED ON OLR | RESET DONE | 11:10:00 | 11:20:00 | |
| 4 | OHP | CO-27A | REPORTED PULL CHORD NOT HEALTHY FOUND P/C OPERATED | PULL CHORD RESET DONE THAN OK | 12:00:00 | 12:10:00 | |
| 5 | CHP | CC-54 | TRIPPED ON OLR (20TIMES) | RESET DONE | 07:00:00 | 13:50:00 | |
| 6 | CHP | CC-51 | MPD TRIP (15TIMES) FEEDING CONVEYOR STOP | RESET DONE | 09:00:00 | 13:30:00 | |
| 7 | CHP | CC-38 SCR-6 | REPORTED B/C STOPPING FREQUENTLY CHECKED AND FOUND SIGNAL PROBLEM | INTERLOCK ZSS KEPT IN LINE THAN OK | 11:30:00 | 11:40:00 | |
| 8 | CHP | CC-125 | TRIPPED ON OLR | RESET DONE | 12:15:00 | 12:25:00 | |
| 9 | WT | ALL PUSHERS | REPORTED NOT MOVE COMMUNICATION PROBLEM | POWER RE-CYCLE LC-1, 2B | 11:00:00 | 12:00:00 | |