



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/05/2025

Shift: C

Incharge(s): V Balaji Naik, G Eswara Rao

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------------------------|---|--|----------------------------------|----------------------------------|--|
| 1 | OHP | Stacker on CO22(Chute vibrator) | Starter tripped | Reset done | 22:45:00 | 23:00:00 | |
| 2 | OHP | CO26 | electrical olr acted | Reset done | 03:50:00 | 04:00:00 | |
| 3 | OHP | CO25 | Over load acted | Reset done | 05:30:00 | 05:40:00 | |
| 4 | OHP | TBS on CO5a | LT not stopped even in off condition | Push button released properly then ok | 22:40:00 | 23:00:00 | some times start push button is not releasing properly may check further |
| 5 | CHP | CC114 | Over load tripped | Reset done | 01:10:00 | 01:20:00 | |
| 6 | CHP | CC114 | BRS not healthy found return cable damaged | Jointing done then ok | 22:35:00 | 22:45:00 | |
| 7 | CHP | CC131 | Tripped on over load due to over load due to deck sheets informed to operation(4 times) | Reset done | 03:35:00 | 03:40:00 | |
| 8 | CHP | CC54 | Over load acted due to jamming (4 times) | Reset done | 22:35:00 | 22:40:00 | |
| 9 | CHP | CC44 | OLR acted 2 times checked belt is in over load | Informed to operation and olr reset done | 00:00:00 01:10:00 03:00:00 | 00:20:00 01:35:00 03:05:00 | |
| 10 | CHP | SCR2 on CC35 | LT not working found over tension limit acted | Reset done then ok | 05:20:00 23:50:00 | 05:40:00 00:10:00 | |
| 11 | CHP | SCR5 on CC32 | LT not working found PCRD over load relay acted | Reset done | 05:15:00 | 05:25:00 | |



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/05/2025

Incharge(s): V Balaji Naik,G Eswara Rao

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|------------|---|------------|----------|----------|---------|
| 12 | WT | CT1 Inhaul | Over load acted | Reset done | 22:30:00 | 22:40:00 | |
| 13 | WT | OT1 | Not rotating found drive2 tripped on PGF1 fault | Reset done | 02:50:00 | 03:00:00 | |