



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 18/06/2025

Area: IOSA

| Equipment | Job |
|--------------------------|---|
| OC-15A , OC-17A | BRAKE PANEL GOT RUSTED AND DAMAGED CONDITION . ISOLATED FROM SUPPLY. |
| OC-11A | ETHERNET CABLE LAYED FROM RMU TO RADIO MODEM |
| TBS | MAINTENANCE DONE ON RADIO MODEM PANEL AND RADIO MODEM. |
| OC-11A | MAINTENANCE DONE ON RADIO MODEM PANEL AND RADIO MODEM. |
| LBDS-2 AIRCOMPRESSOR-1 | NOT HEALTHY, CHECKED CIRCUIT , RACKED OUT VCU AND OPERATED IN LOCAL, TEST POSITION. |
| OC-17A | FIELD DEVICES FEEDBACK CHECKED. |
| OC-21A,OC-23A AND OC-27A | MAINTENANCE DONE ON VACCUM CONTACTOR UNIT AND TESTED IN RACKED OUT IN LOCAL. |
| LIGHTING DEFECTS | RECTIFIED LIGHTING DEFECTS IN TBS AND WOBR |