



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 09/02/2026

Incharge(s): Nagendra Midde

Shift: C

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-------------------------------|---|-----------------------------------|----------------------|----------------------|---------|
| 1 | OHP | TBS ON CO 5A NO DRIVE RUNNING | CONTROL MADE ON | THEN OK | 03:15:00 | 03:30:00 | |
| 2 | OHP | CO 26 | OLR ACTED | RESET | 00:50:00 | 01:00:00 | |
| 3 | OHP | TBS ON CO 20 | LBC OLR ACTED | RESET | 00:15:00 | 00:30:00 | |
| 4 | OHP | BRC ON CO 32 LT | SKEW ACTING FREQUENTLY | INFORMED TO MECH | 05:00:00 | 05:20:00 | |
| 5 | CHP | SCR 2 ON CC 40 | SLEW DRIVE TRIPPED | RESET | 23:30:00 | 23:40:00 | |
| 6 | CHP | CC 108 | OLR ACTED | RESET | 23:50:00 | 23:55:00 | |
| 7 | CHP | CC 31 | OLR ACTED | RESET | 02:30:00 | 02:40:00 | |
| 8 | CHP | CC 51 | FEEDING CONV OLR ACTED | RESET | 23:00:00 | 00:30:00 | 3 TIMES |
| 9 | CHP | CC 54 | OLR ACTED | RESET | 00:30:00 | 02:50:00 | 5 TIMES |
| 10 | CHP | CC 53 | OLR ACTED | RESET | 01:50:00 02:25:00 | 01:55:00 02:30:00 | |
| 11 | CHP | CC 29 | POSITION BIT ON CC 33 | BYPASSED DUE TO STRIKER BENT | 03:00:00 | 03:15:00 | |
| 12 | WT | OT5 | CONTROL MCB TRIPPED IN PLC PANEL AND ONE GLASS FUSE BLOWN | CONTROL MADE ON AND FUSE REPLACED | 23:10:00 | 23:50:00 | |