



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 05/06/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc on co 34	B/C OLR ACTED	RESET	00:00:00	00:15:00	
2	OHP	CO 29	OLR ACTED(2TIMES)	RESET	01:00:00	01:15:00	
3	OHP	CO 35	OLR ACTED	RESET	03:00:00	03:55:00	2 TIMES
4	OHP	CO 26	OLr acted	reset	04:15:00	04:30:00	
5	OHP	CO 15	OLR acted	reset	23:30:00	23:45:00	
6	CHP	CC 32 SCR 5	LT not working, OT acted	released OT	23:17:00	23:28:00	
7	CHP	CC 32	OLR acted	reset	03:25:00	03:30:00	
8	CHP	CC 35 SCR 2	BC not running, signal missing	signal came and healthy	01:20:00	01:25:00	
9	CHP	cc 117	olr acted	reset	22:55:00	23:04:00	
10	CHP	cc 54	olr acted	reset	01:50:00	01:55:00	3 times
11	CHP	cc 51	OLR ACTED	RESET	23:50:00	23:55:00	
12	CHP	CC 51	belt sway acted	reset it	01:15:00	01:26:00	
13	CHP	CC 131	olr acted	reset	01:30:00	01:35:00	3 times