



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 18/09/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav, Arnab Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on co 26	slew not working drive tripped	reset	18:15:00	18:30:00	
2	OHP	VS 1A	olr acted	reset	16:25:00	16:30:00	
3	OHP	co 11(c)	tripped in overload	reset	17:00:00	17:10:00	