



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 26/05/2025

Area: OHP

Equipment	Job
tt-2 on co-21	posiiton bit is byapssed at io rack , suspecting postion cable to cjb got cut, and cable is under heavy spillage material, informed operation to clear the spillage.