



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 01/10/2025

Area: WT

Equipment	Job
EOT Crane (O)	Main hoist UP cantactor 2C1 replaced (,110A,240V ,BCH)
MIS	OT 1,2,3 and 4 hopper area light fittings cleaning done
OP 5	After rake maintenance done, bottom C clamp adjusted
OP 4	After rake maintenance done,2 nos lugs replaced in D6