



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/11/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-22	REPORTED ALL DRIVES ARE NOT WORKING FOUND MAIN CONTROL OFF CONDITION	MADE ON THAN OK	09:25:00	09:35:00	
2	OHP	TBS ON CO-7A	REPORTED BOTH BOOMS UP/DOWN NOT WORKING LIMITS TIE WITH ROPE	LIMITS RELEASED THAN OK	12:15:00	12:30:00	
3	OHP	CC-38 SCR-6	LT NOT TAKING PLACE LT DRIVE TRIPPED	RESET DONE	08:45:00	08:55:00	
4	CHP	CC-54	TRIPPED ON OLR (5 TIMES)	RESET DONE	06:40:00	08:30:00	
5	CHP	CC-52	MPD TRIPPED	RESET DONE	12:00:00	12:10:00	
6	CHP	CC-55	TRIPPED ON OLR	RESET DONE	13:10:00	13:15:00	
7	CHP	CC-39 SCR-2	REPORTED LT NOT TAKING PLACE FOUND PCRD O/T ACTED ( 4TIMES)	RELEASED	08:25:00 11:00:00 13:15:00 13:40:00	08:35:00 11:10:00 13:25:00 13:55:00	
8	CHP	CC-32 R-1	REPORTED B/C NOT RUNNING FOUND INTERLOCK ZSS CAGE STUCK UP WITH COAL PICK	REMOVED THAN OK	08:50:00	09:00:00	
9	CHP	CC-32	TRIPPED ON OLR	RESET DONE	09:40:00	09:50:00	
10	CHP	CC-33 SCR-5	REPORTED B/C STOPPING ON ZSS CHECKED ZSS CAGE STUCK UP	ZSS CAGE REPLACED WITH NEW ONE THAN OK	10:00:00	10:20:00	
11	CHP	CC-125	TRIPPED ON OLR	RESET DONE	10:40:00	10:50:00	
12	CHP	CC-105 SCR-10	LT NOT TAKING PLACE CHECKED PCRD GUIDE PROBLEM	INFORMED TO MECHANICAL	13:00:00	13:20:00	