



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/06/2025

Shift: C

Incharge(s): Lal Singh, Arnab Roy

| Sl No | Area | Equipment          | Problem                        | Action  | From     | To       | Remarks |
|-------|------|--------------------|--------------------------------|---|----------|----------|---------|
| 1     | OHP  | CO 34              | OLR acted                      | reset done  | 03:50:00 | 03:55:00 |         |
| 2     | OHP  | CO 8A ,<br>BRC     | BC overload acted              | reset done  | 23:55:00 | 00:15:00 |         |
| 3     | OHP  | VF 23              | MPCB tripped in panel and LC 6 | Motor meggar done , found okay and tested   | 22:50:00 | 23:20:00 |         |
| 4     | OHP  | CO 43A             | Pull chord acted               | Tail end right side one pull chord switch problem , switch bypassed                     | 01:00:00 | 01:20:00 |         |
| 5     | OHP  | CO 33M<br>BRC      | Hydraulic pump not starting    | Oil level low, informed to operation  | 00:15:00 | 00:30:00 |         |
| 6     | OHP  | BRC on CO 32       | CT not working                 | Operator cabin side limit switch getting stucked frequently . greasing done , then okay | 00:15:00 | 00:40:00 |         |
| 7     | CHP  | CC 39              | Tripped on overload ( 3 times) | reset done . found jamming in tail end side , informed to operation                     | 22:30:00 | 05:15:00 |         |
| 8     | CHP  | CC 223             | Not running                    | Found that chute sensor acted due to jamming . Informed operation for cleaning          | 00:00:00 | 00:30:00 |         |
| 9     | CHP  | CC 44              | Tripped on overload ( 2 times) | reset done  | 01:00:00 | 03:20:00 |         |
| 10    | CHP  | CC 201             | OLR acted                      | reset done  | 04:15:00 | 04:25:00 |         |
| 11    | CHP  | CC 39 ,<br>SCR 7   | LT not working .               | Drive tripped on overload , reset done  | 01:05:00 | 01:20:00 |         |
| 12    | CHP  | CC 34 ,<br>SCR 2   | Slew and LT not working        | Slew healthy and running . LT PCRD overload acted, reset done                           | 23:40:00 | 00:05:00 |         |
| 13    | CHP  | CC 105 ,<br>SCR 10 | Lights not glowing             | In operator cabin AC MCB tripping , made off . Then remaining MCB s made on.            | 23:10:00 | 23:35:00 |         |



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 15/06/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: C

| Sl No | Area | Equipment    | Problem               | Action         | From                 | To                   | Remarks |
|-------|------|--------------|-----------------------|----------------|----------------------|----------------------|---------|
| 14    | CHP  | CC 26        | BRS kept in circuit   | done           | 22:50:00             | 23:00:00             |         |
| 15    | WT   | CP 1 to CP 4 | Communication problem | Power recycled | 05:15:00<br>22:15:00 | 05:20:00<br>22:20:00 |         |