



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 19/12/2025

Area: WT

Equipment	Job
CO 2 level	one LED tube light installed near hoist panel
C P 3	Panel and Motor side ppm done
OP 10	Motor side ppm done
OP 4,5 and 7	after rake, maintenance done
OP 7	Local P B pendent replaced with 3 switches ( removed pendent used for CO 2)
CO 2 level	Hoist pendent replaced ,panel blowing done and tested,OK
MIS	all cables shifted from store near canteen to OT 5 pump house store room