



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 14/12/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TT-1	LT not taking place	MPCB tripped.Made on and tested okay	07:25:00	07:35:00	
2	OHP	AF-4	Reported tripped	Drive tripped on speed deviation.Reset done	12:00:00	12:10:00	
3	OHP	CO-44 hoist	Reported not working	MCCB tripped in Lc-6 due to overload.Made on.	10:00:00	10:10:00	
4	OHP	WOBR on CO-25	Reported LT not taking place	Brakes adjusted by mechanical and track jamming cleared	10:40:00	11:00:00	
5	OHP	BRC on CO-8A	Reported CT not taking place	Drive tripped.Reset done	13:30:00	13:40:00	
6	CHP	Cc-21	ZSS cage damaged	Replaced and tested okay	07:30:00	07:45:00	
7	CHP	CC-51	Reported tripped	MPD tripped.Feeding conveyor stopped.Reset done(7 times)	07:00:00	13:00:00	
8	CHP	CC-54	Reported tripped	OLR acted due to offcentering and over feeding.Reset done(6 times)	07:50:00	08:20:00	Informed to operation and mechanical
9	CHP	CC-104 SCR-9	Reported luff not working	OLR acted.Reset done	10:18:00	10:25:00	
10	WT	OT-1	Reported tripped	D1 tripped on PGEF fault.Reset done	08:25:00	08:30:00	