



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS ON CO-22	R -LUFF OLR ACTED	RESET DONE	07:20:00	07:35:00	
2	OHP	CO-35	BRS NOT RESETTING	RESET DONE ... NO PROBLEM FOUND	08:00:00	08:15:00	
3	OHP	CR-2A	STOPPING ON ZSS.. PROB PROBLEM	PROB CHANGED	07:30:00	08:05:00	
4	CHP	CC-117	TRIPPED ON OLR	RESET DONE	08:50:00	09:10:00	
5	CHP	CC-54	TRIPPED ON OLR	RESET DONE	09:50:00	10:00:00	
6	CHP	CC-52	MPD TRIPPED 2 TIMES	RESET DONE	11:20:00	13:00:00	
7	CHP	CC-51A	MOTOR TRIPPED 3 TIMES	RESET DONE	10:34:00	10:42:00	
8	CHP	CC-51	MPR TRIPPED 2 TIMES	RESET DONE	10:30:00	10:45:00	
9	WT	OT-1	D2 TRIPPING IN PGF-4 FAULT	2 ENCODERS CHANGED	09:35:00	11:50:00	
10	WT	CO-3	STOPPING IN ZSS	PROB ADJUSTED	08:40:00	08:55:00	