



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 22/11/2025

Area: WT

Equipment	Job
MIS	2 nos remotes for E O T cranes (coal and ore) recived and tested ,OK
OP 6	Main cantactor in side the pusher (vaccum 3TF68) replaced and tested
OP 6	D5 checked found winding earth fault in side motor ,packing provided,
LC 2A and 2B	ground sub station panel maintenance done for OP 1 to 5,7 and 8
OP 1,2,6 and 7	after rake maintenance done