



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/12/2025

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------------|--------------------------------------------------------------------|--------------------------------------------------------------------------------------------|----------------------|----------------------|---------|
| 1 | OHP | brc on co-28 | CT NOT TAKING PLACE FOUND CONTROL MCB TRIPPED | MADE ON | 13:10:00 | 13:20:00 | |
| 2 | OHP | TBS ON CO-19 | LT NOT TAKING PLACE FOUND THRUSTER BRAKE MCB TRIPPED | MADE ON THAN OK | 11:20:00 | 11:30:00 | |
| 3 | OHP | BRC ON CO-34 | REPORTED B/W-1 NOT RUNNING FOUND DMPR PLUG LOOSE | FIXED PROPER THAN OK | 08:00:00 | 08:20:00 | |
| 4 | OHP | CO-68 | REPORTED STOPPING ON ZSS FOUND ZSS CAGE STUCK UP AND PROBE DAMAGED | ZSS BYPASSED TEMPORARY CAGE FREE IT ZSS PROBE REPLACED WITH NEW PROBE THAN KEPT IN CIRCUIT | 07:45:00 | 08:30:00 | |
| 5 | CHP | CC-54 | TRIPPED ON OLR (2TIMES) | RESET DONE | 11:30:00 12:10:00 | 11:35:00 12:15:00 | |
| 6 | CHP | CC-33 SCR-5 | LUFF NOT WORKING OLR TRIP | RESET DONE | 06:35:00 | 06:45:00 | |
| 7 | CHP | CC-111 SCR-8 | SIGNAL MISSING | LT MOVE F/D THAN OK | 06:25:00 | 06:35:00 | |
| 8 | CHP | CC-40 SCR-2 | LT NOT TAKING PLACE PCRD O/T ACTED | RELEASED THAN OK | 08:50:00 | 09:05:00 | |
| 9 | CHP | CC-125 | TRIPPED ON OLR | RESET DONE | 09:45:00 | 09:50:00 | |
| 10 | CHP | CC-201,CC-203 | TRIPPED ON OLR | RESET DONE | 09:50:00 | 09:55:00 | |
| 11 | CHP | CC-111 SCR-8 | LT NOT TAKING PLACE PCRD O/T ACTED | RELEASED | 10:00:00 | 10:10:00 | |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 01/12/2025

Incharge(s): K SANKARA RAO

Shift: A

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|----------------------------------------------|---------------------|----------|----------|---------|
| 12 | CHP | CP-3 | REPORTED NOT MOVE FOUND LC-10A I/C-2 TRIPPED | B/C CHARGED THAN OK | 09:00:00 | 09:20:00 | |