



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/09/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 66 OLR	WIRE LOOSE IN RL5	TIGHTENED	14:30:00	14:45:00	
2	OHP	wbr on co-29	MPCB TRIPPED	RESET DONE	19:50:00	20:10:00	
3	CHP	CC 54	OLR ACTED	RESET	16:00:00	16:10:00	
4	CHP	SCR 4 ON CC 31	PCRD CABLE FALLEN DUE TO GUIDE PROBLEM	WINDING DONE AFTER MECH CLEARANCE	15:30:00	16:00:00	
5	CHP	R 1 ON CC 33	SLWE DRIVE TRIPPED	RESET	15:20:00	15:40:00	
6	CHP	SCR 3 ON CC 39	B/C NOT RUNNING DUE TO REC CHUTE JAMMING	INFORMED TO OPRN	18:45:00	19:00:00	
7	CHP	CC32	OLR ACTED	RESET	19:10:00	19:25:00	
8	CHP	CC 26	T/T CABLE GOT CUT	JOINT DONE	18:00:00	18:30:00	
9	CHP	S 1 AND SCR 3	INTERCHANGED	BETWEEN CC 39 AND CC 40	14:30:00	18:00:00	