



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/10/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-32	REPORTED CT NOT TAKING PLACE CHECKED AND FOUND CT POWER OFF CONDITION	CT POWER MADE ON THAN OK	19:00:00	19:15:00	
2	CHP	CC-32 R-1	YARD TO BC ZSS INTERLOCK PROB PROBLEM	PROB CHANGED	15:40:00	16:20:00	
3	CHP	CC-37 SCR-7	PCRD OLR ONE PHASE BURNT	OLR CHANGED AND TESTED	19:05:00	19:45:00	
4	CHP	CC-51	MPD TRIPPED 4 TIMES	RESET DONE	19:00:00	20:35:00	
5	CHP	cc-33 SCR-5	LT NOT WORKING PCRD OT AND CABLE ZIG ZAG	RELESED AND CABLE WINDING DONE WITH MECH	14:40:00	15:00:00	
6	WT	OP-4	NOT MOVE CHECKED AND FOUND DRIVE -3 OLR ACTED	RESET DONE	16:00:00	16:30:00	PUSHER COUPLING TIME
7	WT	CO-3	STOPPING ON ZSS FOUND ZSS PROBE LOOSE	ZSS PROBE FIXED PROPERLY THAN OK	18:00:00	18:15:00	
8	WT	OT-1	TRIPPED ON PGF -1 FAULT	RESET DONE	21:00:00	21:10:00	
9	IOSA	BRC	HYDRAULIC PUMP MCCB TRIPPED	RESET DONE AND TESTED	16:20:00	16:40:00	