



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/07/2025

Shift: B

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 26	OLR ACTED	RESET	19:40:00	19:50:00	
2	OHP	VS1A	OLR ACTED	RESET	20:40:00	20:50:00	
3	OHP	TBS ON CO 7A	LT DRIVE TRIP	RESET	15:15:00	15:30:00	
4	OHP	CO 14	SHOWING RED CONTROL FUSE BLOWN IN CJB	REPLACED	16:15:00	16:30:00	
5	OHP	WOBR ON CO 6A	LT DRIVE TRIP	M5 POWER DISCONNECT AND DRIVE RESET THAN OK	14:15:00	14:30:00	
6	OHP	CO 76R	ZS CAGE STUCK UP MATERIAL	MATERIAL REMOVED AND ZS KEPT IN CIRCUIT	14:30:00	14:45:00	
7	CHP	CC 28 F/G	MPCB TRIP	RESET	17:20:00	17:30:00	
8	CHP	CC 33 SCR 4	B/C NOT RUNNING C/S ACTED	SENSOR CLEANED THAN OK	14:55:00	15:10:00	
9	CHP	CC 112 SCR 8	B/C NOT RUNNING	WRONG COMPLAINT	16:55:00	17:10:00	
10	CHP	CC 34 SCR 2	SLEW NOT TAKING P-LACE DRIVE TRIP	RESET	17:10:00	17:25:00	
11	CHP	CC 38 SCR 8	B/C NOT RUNNING MECH PROBLEM	IN FORMED TO MECH	18:30:00	18:40:00	
12	CHP	CC 105 SCR 10	B/C NOT RUNNING CONTROL MCB TRIP	RESET	20:45:00	21:00:00	
13	CHP	CC 54	OLR ACTED (2TIMES)	RESET	17:20:00	21:00:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/07/2025

Incharge(s): K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	CHP	CC 131	OLR ACTED	RESET	17:45:00	17:50:00	
15	CHP	CC 114	OLR ACTED	RESET	20:45:00	20:50:00	
16	CHP	CC 117	OLR ACTED	RESET	21:05:00	21:25:00	
17	CHP	CC 117	OLR ACTED	RESET	21:05:00	21:25:00	
18	CHP	VF 3	OLR ACTED	RESET	21:35:00	21:45:00	
19	WT	OC 1A	STOPPING ON ZS DUE TO JAMMING	IN FORMED TO OPERATION	20:00:00	20:30:00	
20	WT	LC 9	I/C 2 TRIP EARTH FAULT	B/COUPLER CHARGED AND CM 3 CMV2 OFF	20:30:00	21:15:00	