



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/07/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 35	OLR ACTED	RESET	08:20:00	08:30:00	
2	OHP	CO 29	STOPPING ON ZS ZS CAGE STUCK UP	ZS CAGE REPLACED WITH NEW	08:30:00	08:45:00	
3	OHP	BRC ON CO 31	B/C OLR ACTED	RESET	11:30:00	11:45:00	
4	OHP	WOBR ON CO 25	LT NOT TAKING PLACE M 1 OLR ACTED	RESET	13:35:00	13:50:00	
5	CHP	CC 15	OLR ACTED	RESET	13:20:00	13:25:00	
6	CHP	CC 51	MPD TRIP	RESET	09:10:00	09:15:00	
7	CHP	CC 131	OLR ACTED (2TIMES)	RESET	11:40:00	12:00:00	
8	CHP	CC 53	OLR ACTED	RESET	13:00:00	13:10:00	
9	CHP	CC 52	OLR ACTED	RESET	12:55:00	13:00:00	
10	CHP	CC 55	STOPPING ON ZS CHECKED BELT SNAP	IN FORMED TO OPERATION	07:35:00	07:50:00	
11	CHP	CC 112 SCR 8	LT COMMEND GIVEN B/C STOPPED	LT GIVEN LOCAL MODE	07:20:00	07:40:00	
12	CHP	CC 36	NOT RUNNING CHECKED MAIN CONTROL BUS WIRE LOOSE	TITEN THAN OK	09:00:00	09:10:00	
13	CHP	CC 33 SCR 4	SLEW NOT TAKING PLACE MATERIAL JAMMING	IN FORMED TO OPERATION	09:55:00	10:05:00	