



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 29/08/2025

Incharge(s): Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBR on CO 29	LT not taking place	M4 tripped, reset done	07:40:00	08:00:00	
2	OHP	WOBR on CO 26	Slew not working	drive tripped, reset done	08:15:00	08:25:00	
3	OHP	CO 58	Pull chord acted	reset done	10:00:00	10:18:00	
4	CHP	CC 114	Tripped on overload	reset done	12:35:00	12:40:00	
5	CHP	CC 39, SCR 7	BC not working	chute sensor acted, cleaned ok	07:35:00	07:55:00	
6	CHP	CC 105 , SCR 10	Slew and BW not working	MPCB tripped , made on	08:55:00	09:15:00	
7	CHP	cc 35 , s 2	Slew not working	30 degree limit acted due to material . Cleaning done then healthy	07:30:00	08:00:00	
8	CHP	CC 39 , SCR 7	LT not working due to track jamming	Informed to operation for cleaning	10:00:00	10:20:00	
9	CHP	CC 40	BRS to be bypassed as per opn request	bypassed in IO rack	11:00:00	11:15:00	
10	WT	AF 3	Tripped on pgf 1 fault	reset done	12:15:00	12:20:00	