



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 13/10/2025

Incharge(s): Saurabh Kumar Yadav

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RCO1A	not healthy BRS acted,brs neutral missing,neutral wire TB cut at CJB	relugged done and terminated	12:05:00	12:25:00	
2	OHP	CO 84	OLr acted	reset	12:10:00	12:15:00	
3	OHP	CO 26	OLR acted	reset	13:35:00	13:45:00	
4	CHP	CC 32 R1	LT not working,control cable got burn	cable rejoined	06:15:00	07:00:00	
5	CHP	CC 35 SCR 5	LT not working,drive tripped	reset	06:50:00	07:00:00	
6	CHP	CC 44	OLR acted	reset	08:00:00	08:05:00	
7	CHP	CC 38 SCR6	slew not working,contactor problem	general shift replaced	09:30:00	09:45:00	
8	CHP	CC 32 R1	B/c not running,control loose connection in MCB	tightened	10:30:00	10:55:00	
9	CHP	CC 40 SCR3	LT not working,Emergency PB acted	released Emergency PB	08:10:00	08:20:00	
10	CHP	CC 51	mpd trips 2 times	reset	07:25:00	07:30:00	
11	CHP	CC 28 TT on CC 31	bit missing,fuse blown	fuse replaced	06:15:00	06:30:00	
12	WT	OT1	m1 tripped on PGF1 fault	reset	08:30:00	08:40:00	
13	WT	OT 3	D1 tripped in pgf4 fault	reset	11:30:00	11:35:00	
14	IOSA	BRC	CT not working	power recycle done than ok	11:00:00	11:10:00	