



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/12/2025

Area: WT

Equipment	Job
CM 7	Data cable panel blowing done and 2 nos tubes replaced
CO 3 and 4 area	Lighting problem rectified, 1 no 200 W LED and 15 mtrs cable replaced
CO 4(Belt)	NGEF module ,sliding contact replaced
OP 3,4,5,7 and 9	After rake maintenance done