



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 17/05/2025

Incharge(s): G Eswara Rao

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|--|-------------------------------------|----------|----------|---------|
| 1 | OHP | brc on co 33m | bw s are not running/oil level low | inform to operation and mech. | 16:15:00 | 16:30:00 | |
| 2 | OHP | co 34 | tripped on thermal olr . | reset done | 20:00:00 | 20:15:00 | |
| 3 | CHP | R1 on cc31 | luffing not working/oil level low inform to mech. and ope. | . | 19:30:00 | 19:45:00 | |
| 4 | CHP | R1 on cc31 | bc not running/olr tripped in mpd | reset done | 20:00:00 | 20:10:00 | |
| 5 | CHP | cc131 | tripped on olr/due to jamming | reset done | 20:40:00 | 20:45:00 | |
| 6 | CHP | cc 130 | zss acted/didnt found any problem | power and control recycled then ok. | 19:30:00 | 19:45:00 | |
| 7 | WT | co 3 b/d | tripped on olr due to jamming | reset done | 18:30:00 | 18:40:00 | |