



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 16/02/2026

Area: IOSA

Equipment	Job
OJH-10A	REMOVED ONE CABLE TROLLEY UNIT FOR DRAWING/ PROCURING SPARES.
BRC	REPLACED FESTOON CABLE TROLLEY DAMAGED WHEELS
OC-11A	CHECKED COMPOSITE CABLE AFTER MATERIAL REMOVAL ON CABLE.
OC-33A	SHUTTLE CONVEYOR FESTOON CABLE AND ASSEMBLY CLEANING AND CHECKING.
BRC	LT M6 MPCB REPLACED.
OC-19A	PPM DONE ON SUMP PUMPS AT H/E and T/E.