



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/02/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	REPORTED P/C NOT HEALTHY GLASS FUSE BLOWN DUE TO EARTH FAULT IN FIELD	FIELD WIRES REMOVED AND P/C BYPASSED IN CJB	06:40:00	06:55:00	
2	OHP	VF-19	REPORTED NOT HEALTHY FOUND MPCB TRIP DUE TO R-PHASE RUBBED WITH GI PIPE	R-PHASE TAPPING WAS DONE THAN MPCB MADE ON OK	10:00:00	10:20:00	
3	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	10:30:00 11:55:00	10:40:00 12:00:00	
4	OHP	BRC ON CO-32	B/W S NOT RUNNING OIL LOW LEVEL	INFORMED TO OPERATION	10:30:00	10:40:00	
5	CHP	CC-51	MPD TRIP ( 2 TIMES)	RESET DONE	07:00:00 08:20:00	07:05:00 08:25:00	
6	CHP	CC-117	OLR ACTED (2 TIMES)	RESET DONE	09:00:00 09:50:00	09:10:00 10:00:00	
7	CHP	CC-213	OLR ACTED	RESET DONE	07:30:00	07:40:00	
8	CHP	CC-125	OLR ACTED	RESET DONE	09:00:00	09:05:00	
9	CHP	CC-40 SCR-2	LUFFING NOT WORKING OIL LOW LEVEL	INFORMED TO MECHANICAL	11:30:00	11:45:00	
10	CHP	CC-104 SCR-7	REPORTED B/C STOPPING ZSS CAGE STUCK UP COAL PICK	REMOVED THAN OK	12:50:00	13:00:00	
11	CHP	CC-104 SCR-7	SLEW LEFT NOT WORKING IN XMD SETTING PROBLEM	IN XMD MA SETTINGS CHANGED THAN OK	08:40:00	09:00:00	
12	CHP	CC-221	REPORTED HEALTHY STOP DRIVE OUT PUT C-2 POWER CONTACTOR PROBLEM	POWER CONTACTOR BYPASSED	11:40:00	12:00:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/02/2026

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	IOSA	BRC ON OC-15A	B/C STOPPING ON ZSS CAGE STUCK UP WITH STONE	STONE REMOVED THAN OK	08:40:00	09:00:00	
14	IOSA	OC-27A	BRS NOT RESET	SENSOR S CLEANED THAN OK	11:05:00	11:20:00	